



**Air Noise Environment**  
Environmental Monitoring and Assessment

# Emissions Monitoring: Talinga Gas Processing Facility

Origin Energy

**Origin Energy**  
**144 Montague Road**  
**West End QLD 4101**

**May 2014**

**Issued: 7 December 2016**

**Prepared by:**  
**Air Noise Environment**  
**ABN: 13 081 834 513**





The results of tests and/or measurements included in this document are traceable to international standards.

Should you have any queries regarding the contents of this document, please contact your nearest Air Noise Environment office:

**Brisbane Office**

A: Unit 3, 4 Tombo Street  
Capalaba, QLD 4157  
T: +61 7 3245 7808  
E: [qld@ane.com.au](mailto:qld@ane.com.au)

**Sydney Office**

A: Level 6, 69 Reservoir Street  
Surry Hills, NSW 2010  
T: +61 2 8217 0706  
E: [nsw@ane.com.au](mailto:nsw@ane.com.au)

**Townsville Office**

A: Level 1, 25 Sturt Street  
Townsville, QLD 4810  
T: +61 7 4722 2724  
E: [qld@ane.com.au](mailto:qld@ane.com.au)





# DOCUMENT CONTROL SHEET

## Document Details

Project Reference: 3737  
Document Title: Emissions Monitoring: Talinga Gas Processing Facility  
Client: Origin Energy  
Document Reference: /home/gh/Desktop/3737 Report02.odt

## Revision History

Version:	Author:	Approved by:	Function:	Signature:
00	Samuel Putland	Gary Hall	Technical Reviewer	
01	Samuel Putland	Gary Hall	Technical Reviewer	<i>G. Hall</i>
02	Samuel Putland	Gary Hall	Technical Reviewer	<i>G. Hall</i>

### Copyright:

Air Noise Environment retains ownership of the copyright to all reports, drawings, designs, plans, figures and other work produced by Air Noise Environment Pty Ltd during the course of fulfilling a commission. The client named on the cover of this document shall have a licence to use such documents and materials for the purpose of the subject commission provided they are reproduced in full or, alternatively, in part with due acknowledgement to Air Noise Environment. Third parties must not reproduce this document, in part or in full, without obtaining the prior permission of Air Noise Environment Pty Ltd.

### Disclaimer:

This document has been prepared with all due care and attention by professional environmental practitioners according to accepted practices and techniques. This document is issued in confidence and is relevant only to the issues pertinent to the subject matter contained herein. Air Noise Environment Pty Ltd holds no responsibility for misapplication or misinterpretation by third parties of the contents of this document. If the revision history does not state that a Final version of the document has been issued, then it remains a draft. Draft versions of this document should not be relied upon for any purpose by the client, regulatory agencies or other interested parties.

Where site inspections, testing or fieldwork have taken place, the report is based on the information made available by the client or their nominees during the visit, visual observations and any subsequent discussions with regulatory authorities. It is further assumed that normal activities were being undertaken at the site on the day of the site visit(s).

The validity and comprehensiveness of supplied information has not been independently verified and, for the purposes of this report, it is assumed that the information provided to Air Noise Environment Pty Ltd for the purposes of this project is both complete and accurate.





## Table of Contents

	Executive Summary	5
	Table 1: Summary of results.	5
1	Introduction	7
2	Methodology	9
2.1	Emission Testing	9
2.2	Deviation from Methods	9
3	Results	10
3.1	Introduction	10
3.1.1	Process Conditions	10
3.1.2	Monitoring Results	11
	Appendix A – Glossary of Terms	17
	Appendix B – Calibration Record	21

## Index of Tables

Table 1: Summary of results.	5
Table 1.1: Monitoring locations and parameters.	7
Table 2.1: Summary of Emission Monitoring Methods.	9
Table 3.1: Process Conditions During Emissions Monitoring for Reciprocating and Screw Compressors.	10
Table 3.2: Process Conditions During Emissions Monitoring for Power Generators.	11
Table 3.3: Flow and Sample Characteristics for Reciprocating Compressors.	12
Table 3.4: Flow and Sample Characteristics for Screw Compressors.	13
Table 3.5: Flow and Sample Characteristics for Power Generators.	15





# Executive Summary

Origin Energy operates a Gas Processing Facility (GPF) at Talinga and forms an integral part of the Australia Pacific LNG (APLNG) Project. The site is located at 4940 Kogan-Condamine Road Qld 4413

The existing Talinga GPF has an output of 90 TJ/day and comprises the following emission sources:

- 12 Waukesha L7042GSI rich-burn gas-fired screw compressor engines
- 5 Caterpillar G3612 gas-fired engines (2 stacks per compressor)
- 3 Caterpillar G3406 gas-fired engines

Table 1 Presents a summary of emissions from monitoring completed at the Origin Talinga Gas Processing Facility during the period 1<sup>st</sup> - 3<sup>rd</sup> May 2014.

Table 1: Summary of results.

Release Point		Velocity (m/s) <sup>1</sup>	NO <sub>x</sub> (expressed as NO <sub>2</sub> ) (g/s) <sup>1</sup>
Reciprocating Compressors	K4406-01.1	15.5	0.1424
	K4406-01.2	25.7	0.2101
	K4406-02.1	18.6	0.2476
	K4406-02.2	33.6	0.3778
	K4406-03.1	19.7	0.2843
	K4406-03.2	32.4	0.4129
	K4406-04.1	19.5	0.3387
	K4406-04.2	34.5	0.5832
	K4406-05.1	18.5	0.2590
	K4406-05.2	33.5	0.2929
Screw Compressors	K4404-01.1	31.3	5.6796
	K4404-02.1	30.8	5.2669
	K4404-03.1	33.3	2.0880
	K4404-04.1	32.6	4.0892
	K4404-05.1	33.3	4.3230
	K4404-07.1	33.3	3.5081
	K4404-08.1	32.2	4.6345
	K4404-09.1	34.6	3.5165
	K4404-10.1	35.7	4.9851
	K4404-11.1	36.1	6.5891
	K4404-12.1	35.4	7.2835





Release Point		Velocity (m/s) <sup>1</sup> .	NO <sub>x</sub> (expressed as NO <sub>2</sub> ) (g/s) <sup>1</sup> .
Power Generation	G4408-01.1	6.0	0.3892
	G4408-02.1	6.6	0.3931
	G4408-03.1	6.8	0.4838

*1. K4404-06.1 not sampled due to engine currently not in operation.*






# 1 Introduction

Origin Energy commissioned Air Noise Environment Pty Ltd to conduct monitoring of air emissions from their Talinga Gas Processing Facility as part of their requirements under the Queensland Department of Environment and Heritage Protection (EHP) for the facility. Table 1.1 details the monitoring locations and the monitoring performed at each location. The monitoring was completed during the period 1<sup>st</sup> - 3<sup>rd</sup> May 2014. Screw compressor K4404-06.1 was not tested as it is currently not in operation. The engines sampled are included in Table 1.1.

Table 1.1: Monitoring locations and parameters.

Parameter	NO <sub>x</sub>	Velocity	Temperature & Moisture	O <sub>2</sub> , CO <sub>2</sub>
Reciprocating Compressor K4404-01.1	✓	✓	✓	✓
Reciprocating Compressor K4404-01.2	✓	✓	✓	✓
Reciprocating Compressor K4404-02.1	✓	✓	✓	✓
Reciprocating Compressor K4404-02.2	✓	✓	✓	✓
Reciprocating Compressor K4404-03.1	✓	✓	✓	✓
Reciprocating Compressor K4404-03.2	✓	✓	✓	✓
Reciprocating Compressor K4404-04.1	✓	✓	✓	✓
Reciprocating Compressor K4404-04.2	✓	✓	✓	✓
Reciprocating Compressor K4404-05.1	✓	✓	✓	✓
Reciprocating Compressor K4404-05.2	✓	✓	✓	✓
Screw Compressor K4404-01.1	✓	✓	✓	✓
Screw Compressor K4404-02.1	✓	✓	✓	✓
Screw Compressor K4404-03.1	✓	✓	✓	✓
Screw Compressor K4404-04.1	✓	✓	✓	✓
Screw Compressor K4404-05.1	✓	✓	✓	✓
Screw Compressor K4404-07.1	✓	✓	✓	✓
Screw Compressor K4404-08.1	✓	✓	✓	✓
Screw Compressor K4404-09.1	✓	✓	✓	✓
Screw Compressor K4404-10.1	✓	✓	✓	✓
Screw Compressor K4404-11.1	✓	✓	✓	✓
Screw Compressor K4404-12.1	✓	✓	✓	✓
Power Generator G4408-01.1	✓	✓	✓	✓





Parameter	NO <sub>x</sub>	Velocity	Temperature & Moisture	O <sub>2</sub> , CO <sub>2</sub>
Power Generator G4408-02.1	✓	✓	✓	✓
Power Generator G4408-03.1	✓	✓	✓	✓

The monitoring of air emissions at the Talinga Gas Processing Facility was completed during normal operating conditions. Any factors that may have affected the monitoring results were not observed by, or brought to the notice of Air Noise Environment (ANE) staff except where noted in this report.







## 2 Methodology

### 2.1 Emission Testing

Table 2.1 below lists the Methods used when undertaking emission monitoring at the Talinga Gas Processing Facility.

All air quality monitoring undertaken by the Company has been undertaken in accordance with the methods identified in Table 2.1 below unless as specified in Section 2.2.

Table 2.1: Summary of Emission Monitoring Methods.

Measurement Parameter	Method Equivalency
Sampling Positions	<b>AS4323.1-1995</b> Method 1: selection of sampling positions
Velocity, Flowrate and Temperature	<b>AS 4323.2-1995</b> Stationary Source Emissions - Method 2: Determination of Total Particulate Matter - Isokinetic Manual Sampling - Gravimetric Method
Oxygen and Carbon Dioxide	<b>USEPA Method 3A</b> Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources
Moisture Content	<b>USEPA Method 4</b> Determination of Moisture Content in Stack Gases
Oxides of Nitrogen (NO, NO <sub>2</sub> , NO <sub>x</sub> )	<b>USEPA Method 7E</b> Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental Analyzer Procedure)
Hydrocarbons (C1-C4)	<b>USEPA Method 18</b> Determination of Volatile Organic Compounds (Sample Collection by Gas Bag)

### 2.2 Deviation from Methods

Determination of moisture content was undertaken using a modified Method 4 sampling train. Deviations from USEPA Method 4 included the following –

- Sampling was undertaken at a single point within the exhaust gas stream; and
- A total of three midjet impingers (two with water and one with silica gel) were used in the sampling train to measure moisture content.





## 3 Results

### 3.1 Introduction

The following sections present a summary of results for each sampling location.

#### 3.1.1 Process Conditions

Table 3.1 provides a summary of process conditions during the air emissions monitoring at Talinga Gas Processing Facility.

Table 3.1: Process Conditions During Emissions Monitoring for Reciprocating and Screw Compressors.

Parameter	Average Engine Load (%)	Average Engine RPM
Reciprocating Compressor K4406-01.1	87	846
Reciprocating Compressor K4406-01.2		
Reciprocating Compressor K4406-02.1	87	999
Reciprocating Compressor K4406-02.2		
Reciprocating Compressor K4406-03.1	88	1000
Reciprocating Compressor K4406-03.2		
Reciprocating Compressor K4406-04.1	89	1000
Reciprocating Compressor K4406-04.2		
Reciprocating Compressor K4406-05.1	88	1000
Reciprocating Compressor K4406-05.2		
Screw Compressor K4404-01.1	96	1203
Screw Compressor K4404-02.1	96	1202
Screw Compressor K4404-03.1	97	1199
Screw Compressor K4404-04.1	100	1201
Screw Compressor K4404-05.1	98	1200
Screw Compressor K4404-07.1	99	1205
Screw Compressor K4404-08.1	97	1202
Screw Compressor K4404-09.1	104	1202
Screw Compressor K4404-10.1	103	1202
Screw Compressor K4404-11.1	103	1199





Parameter	Average Engine Load (%)	Average Engine RPM
Screw Compressor K4404-12.1	101	1204

Table 3.2: Process Conditions During Emissions Monitoring for Power Generators.

Parameter	Generator Load (kW)	Average Engine RPM	Combustion Temperature (°C)
Power Generation G4408-01.1	46	1500	34.9
Power Generation G4408-02.1	50	1500	48.7
Power Generation G4408-03.1	47	1499	49.0

### 3.1.2 Monitoring Results

Results of emissions monitoring for Talinga Gas Processing Facility are provided in Table 3.3 and Table 3.4 below for emissions monitoring completed during the period of the 1<sup>st</sup> - 3<sup>rd</sup> May 2014.



Table 3.3: Flow and Sample Characteristics for Reciprocating Compressors.

Parameter	K4406-01.1	K4406-01.2	K4406-02.1	K4406-02.2	K4406-03.1	K4406-03.2	K4406-04.1	K4406-04.2	K4406-05.1	K4406-05.2
Date (dd/mm/yy)	01/05/2014									
Start Time (hh:mm)	16:42	15:53	15:03	14:14	13:18	12:28	11:38	10:47	09:57	08:54
Sample Time (min)	17:10	16:23	15:33	14:44	13:48	12:58	12:08	11:17	10:27	09:24
Sample Volume (m <sup>3</sup> )	0.309	0.336	0.336	0.333	0.314	0.316	0.312	0.316	0.316	0.313
Average Stack Temperature (°C)	323	362	336	403	342	401	337	412	328	395
Stack Diameter (m)	0.50									
Barometric Pressure (KPa)	101.70									
Calculated Stack Moisture (%)	10.2	9.9	10.8	9.8	12.6	9.3	10.9	11.5	11.0	9.5
Carbon Dioxide Percentage (%)	4.90	4.95	5.19	5.09	5.13	4.93	5.36	5.31	5.00	4.68
Oxygen Percentage (%)	11.91	11.80	11.36	11.54	11.44	11.80	11.03	11.13	11.73	12.37
Dry Gas Molecular Weight (g/gmole)	29.26	29.26	29.29	29.28	29.28	29.26	29.30	29.30	29.27	29.24
Average Stack Gas Velocity (m/s)	15.5	25.7	18.6	33.6	19.7	32.4	19.5	34.5	18.5	33.5
Actual Stack Flow Rate (m <sup>3</sup> /s)	3.05	5.04	3.66	6.60	3.87	6.35	3.84	6.77	3.63	6.58
Dry Standard Stack Flow Rate (Nm <sup>3</sup> /s)	1.26	1.96	1.47	2.41	1.51	2.34	1.54	2.39	1.47	2.43

Parameter		K4406-01.1	K4406-01.2	K4406-02.1	K4406-02.2	K4406-03.1	K4406-03.2	K4406-04.1	K4406-04.2	K4406-05.1	K4406-05.2
NO <sub>x</sub> (expressed as NO <sub>2</sub> )	(mg/Nm <sup>3</sup> )	113.1	107.1	168.7	156.7	188.7	176.7	220.6	243.9	175.8	120.3
	(g/s)	0.1424	0.2101	0.2476	0.3778	0.2843	0.4129	0.3387	0.5832	0.2590	0.2929
CO	(mg/Nm <sup>3</sup> )	435.6	451.2	441.6	425.5	485.7	489.0	521.7	518.8	513.9	443.3
	(g/s)	0.5485	0.8849	0.6482	1.0256	0.7315	1.1428	0.8011	1.2407	0.7573	1.0788

Table 3.4: Flow and Sample Characteristics for Screw Compressors.

Parameter	K4404-01	K4404-02	K4404-03	K4404-04	K4404-05	K4404-07	K4404-08	K4404-09	K4404-10	K4404-11	K4404-12
Date (dd/mm/yyyy)	02/05/2014							03/05/2014			
Start Time (hh:mm)	08:30	09:22	10:10	12:56	11:02	12:02	13:50	08:53	10:01	11:06	12:12
Sample Time (min)	09:00	09:52	10:40	13:26	11:32	12:32	14:20	09:23	10:31	11:36	12:42
Sample Volume (m <sup>3</sup> )	0.307	0.265	0.269	0.265	0.287	0.270	0.267	0.263	0.260	0.272	0.273
Average Stack Temperature (°C)	470	453	475	466	467	464	461	479	465	469	474
Stack Diameter (m)	0.35										
Barometric Pressure (KPa)	101.01							100.94			
Calculated Stack Moisture (%)	17.1	20.1	20.8	19.7	20.4	20.6	18.8	20.7	19.6	19.2	20.3
Carbon Dioxide Percentage (%)	10.55	10.50	10.70	10.89	10.88	10.82	10.72	10.91	10.61	10.43	10.70
Oxygen Percentage (%)	1.09	1.16	1.31	0.93	0.97	1.07	1.21	0.84	1.40	1.24	0.83
Dry Gas Molecular Weight (g/g-mole)	29.73	29.73	29.76	29.78	29.78	29.77	29.76	29.78	29.75	29.72	29.74

Parameter		K4404-01	K4404-02	K4404-03	K4404-04	K4404-05	K4404-07	K4404-08	K4404-09	K4404-10	K4404-11	K4404-12
Average Stack Gas Velocity (m/s)		31.3	30.8	33.3	32.6	33.3	33.3	32.2	34.6	35.7	36.1	35.4
Actual Stack Flow Rate (m³/s)		3.02	2.96	3.21	3.14	3.20	3.20	3.09	3.32	3.43	3.47	3.40
Dry Standard Stack Flow Rate (Nm³/s)		0.92	0.89	0.92	0.93	0.94	0.94	0.93	0.95	1.01	1.02	0.99
NO <sub>x</sub> (expressed as NO <sub>2</sub> )	(mg/Nm³)	6193.1	5937.3	2263.4	4411.9	4598.2	3727.7	4978.9	3695.0	4913.6	6433.8	7376.2
	(g/s)	5.6796	5.2669	2.0880	4.0892	4.3230	3.5081	4.6345	3.5165	4.9851	6.5891	7.2835
CO	(mg/Nm³)	4235.2	4862.0	402.8	177.7	383.7	383.0	313.1	301.7	179.1	4507.3	4479.2
	(g/s)	3.8840	4.3130	0.3716	0.1647	0.3608	0.3604	0.2914	0.2872	0.1817	4.6160	4.4229
Methane	(mg/Nm³)	-	-	-	-	-	-	-	513.2	445.2	492.4	500.3
	(g/s)	-	-	-	-	-	-	-	0.3876	0.3630	0.4074	0.3935
Ethane	(mg/Nm³)	-	-	-	-	-	-	-	1.919	2.590	4.106	5.126
	(g/s)	-	-	-	-	-	-	-	0.0014	0.0021	0.0034	0.0040
Ethylene	(mg/Nm³)	-	-	-	-	-	-	-	2.140	1.690	26.79	34.92
	(g/s)	-	-	-	-	-	-	-	0.0016	0.0014	0.0222	0.0275
Propane	(mg/Nm³)	-	-	-	-	-	-	-	<0.039	<0.039	0.118	0.157
	(g/s)	-	-	-	-	-	-	-	<0.00003	<0.00003	0.0001	0.0001
Propylene	(mg/Nm³)	-	-	-	-	-	-	-	0.282	0.038	1.934	2.479
	(g/s)	-	-	-	-	-	-	-	0.0002	0.00003	0.0016	0.0019



Parameter		K4404-01	K4404-02	K4404-03	K4404-04	K4404-05	K4404-07	K4404-08	K4404-09	K4404-10	K4404-11	K4404-12
I-butane	(mg/Nm <sup>3</sup> )	-	-	-	-	-	-	-	0.519	0.908	1.608	1.530
	(g/s)	-	-	-	-	-	-	-	0.0004	0.0007	0.0013	0.0012
Butane	(mg/Nm <sup>3</sup> )	-	-	-	-	-	-	-	<0.078	<0.078	0.078	0.078
	(g/s)	-	-	-	-	-	-	-	<0.00006	<0.00006	0.0001	0.0001
Butylene	(mg/Nm <sup>3</sup> )	-	-	-	-	-	-	-	0.626	0.351	0.776	0.976
	(g/s)	-	-	-	-	-	-	-	0.0005	0.0003	0.0006	0.0008

Table 3.5: Flow and Sample Characteristics for Power Generators.

Parameter	G4408-01.1	G4408-02.1	G4408-03.1
Date (dd/mm/yyyy)	03/05/2014		
Start Time (hh:mm)	14:41	13:58	13:18
Sample Time (min)	15:11	14:28	13:48
Sample Volume (m <sup>3</sup> )	0.271	0.272	0.271
Average Stack Temperature (°C)	332	328	384
Stack Diameter (m)	0.20		
Barometric Pressure (KPa)	100.94		
Calculated Stack Moisture (%)	17.8	14.8	16.8
Carbon Dioxide Percentage (%)	9.09	8.73	9.14
Oxygen Percentage (%)	4.13	4.83	4.01

Parameter		G4408-01.1	G4408-02.1	G4408-03.1
Dry Gas Molecular Weight (g/g-mole)		29.62	29.59	29.62
Average Stack Gas Velocity (m/s)		6.0	6.6	6.8
Actual Stack Flow Rate (m³/s)		0.19	0.21	0.21
Dry Standard Stack Flow Rate (Nm³/s)		0.07	0.08	0.07
NO <sub>x</sub> (expressed as NO <sub>2</sub> )	(mg/Nm³)	5550.7	4897.4	6534.2
	(g/s)	0.3892	0.3931	0.4838
CO	(mg/Nm³)	731.7	786.1	1051.8
	(g/s)	0.0513	0.0631	0.0779



## Appendix A – Glossary of Terms

## APPENDIX A: GLOSSARY OF TERMS

<	The analytes tested for was not detected, the value stated is the reportable limit of detection
µg	Micrograms ( $10^{-6}$ grams)
AS	Australian Standard
dscm	dry standard cubic meters (at 0°C and 1 atmosphere)
g	grams
kg	kilograms
m	metres
m <sup>3</sup>	Cubic Metres, actual gas volume in cubic metres as measured.
mg	Milligrams
min	Minute
mg/m <sup>3</sup>	Milligrams ( $10^{-3}$ ) per cubic metre.
mmH <sub>2</sub> O	Millimetres of water
Mole	SI Unit defined as an amount of a substance that contains as many elementary entities (e.g. atoms, molecules, ions, electrons) as there are atoms in 12 grams of pure Carbon-12 ( <sup>12</sup> C)
N/A	Not Applicable
ng	Nanograms ( $10^{-9}$ grams)
Nm <sup>3</sup>	Normalised Cubic Metres - Gas volume in dry cubic metres at standard temperature and pressure (0°C and 101.3 kPa) and corrected .
ou	Odour Units
°C	Degrees Celsius
µg/m <sup>3</sup>	Micrograms ( $10^{-6}$ ) per cubic metre. Conversions from µg/m <sup>3</sup> to parts per volume concentrations (ie, ppb) are calculated at 25 °C.
ppb / ppm	Parts per billion / million.
PM	Particulate Matter.

## APPENDIX A: GLOSSARY OF TERMS

PM <sub>10</sub> , PM <sub>2.5</sub> , PM <sub>1</sub>	Fine particulate matter with an equivalent aerodynamic diameter of less than 10, 2.5 or 1 micrometres respectively. Fine particulates are predominantly sourced from combustion processes. Vehicle emissions are a key source in urban environments.
sec	Second
Sm <sup>3</sup>	Standardised Cubic Metres - Gas volume in dry cubic metres at standard temperature and pressure (0°C and 101.3 kPa) and corrected to a standardised value ( e.g. 7% O <sub>2</sub> )
STP	Standard Temperature and Pressure (0°C and 101.3 kPa)
TVOC	Total Volatile Organic Compounds. These compounds can be both toxic and odorous.
USEPA	United States Environmental Protection Agency

## Appendix B – Calibration Record



APPENDIX B: MULTI-POINT CALIBRATION			
Test Location	ANE Capalaba	Cylinder No.	461 397
Calibration Date	29-Apr-14		310 459
Testo ID	ANE Testo 01		

APPENDIX B: PRE-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	0.00	0.00	-	0.0	0
	Actual	0.02	0.02	-	0.0	0
	Calibration	-	-	-		
HIGH	Target	15.20	21.30	-	23.6	511
	Actual	15.16	21.40	-	23.4	491
	Calibration	-	-	-	-	511





APPENDIX B: MULTI-POINT CALIBRATION			
Test Location	ANE Capalaba	Cylinder No.	461 397
Calibration Date	29-Apr-14		310 459
Testo ID	ANE Testo 03		

APPENDIX B: PRE-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	-	0.00	0	0.0	0
	Actual	-	0.10	1	1.0	0
	Calibration	-	-	-	-	-
HIGH	Target	-	21.30	995	23.6	511
	Actual	-	21.40	1121	24.0	510
	Calibration	-	-	995	-	-





APPENDIX B: MULTI-POINT CALIBRATION			
Test Location	Origin Talinga	Cylinder No.	461 397
Calibration Date	02-May-14		310 459
Testo ID	ANE Testo 03		

APPENDIX B: PRE-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	-	0.00	0	0.0	0
	Actual	-	0.10	0	0.0	0
	Calibration	-	-	-	-	-
MID	Target	-	-	-	-	-
	Actual	-	-	-	-	-
	Calibration	-	-	-	-	-
HIGH	Target	-	21.30	995	23.6	511
	Actual	-	21.57	942	20.3	493
	Calibration	-	21.30	995	23.6	511





APPENDIX B: MULTI-POINT CALIBRATION			
Test Location	Origin Talinga	Cylinder No.	461 397
Calibration Date	02-May-14		310 459
Testo ID	ANE Testo 01		

APPENDIX B: PRE-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	0.00	0.00	-	0.0	0
	Actual	0.00	0.02	-	0.0	0
	Calibration	-	-	-	-	-
MID	Target	-	-	-	-	-
	Actual	-	-	-	-	-
	Calibration	-	-	-	-	-
HIGH	Target	15.20	21.30	-	23.6	511
	Actual	15.12	21.62	-	19.6	492
	Calibration	-	21.30	-	23.6	511







APPENDIX B: MULTI-POINT CALIBRATION			
Test Location	Origin Talinga	Cylinder No.	461 397
Calibration Date	02-May-14		310 459
Testo ID	ANE Testo 03		

APPENDIX B: PRE-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	-	0.00	0	0.0	0
	Actual	-	0.10	0	0.0	0
	Calibration	-	-	-	-	-
MID	Target	-	-	-	-	-
	Actual	-	-	-	-	-
	Calibration	-	-	-	-	-
HIGH	Target	-	21.30	995	23.6	511
	Actual	-	21.57	942	20.3	493
	Calibration	-	21.30	995	23.6	511





APPENDIX B: MULTI-POINT CALIBRATION			
Test Location	Origin Talinga	Cylinder No.	461 397
Calibration Date	02-May-14		310 459
Testo ID	ANE Testo 01		

APPENDIX B: PRE-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	0.00	0.00	-	0.0	0
	Actual	0.00	0.02	-	0.0	0
	Calibration	-	-	-	-	-
MID	Target	-	-	-	-	-
	Actual	-	-	-	-	-
	Calibration	-	-	-	-	-
HIGH	Target	15.20	21.30	-	23.6	511
	Actual	15.12	21.62	-	19.6	492
	Calibration	-	21.30	-	23.6	511





APPENDIX B: MULTI-POINT CALIBRATION 350			
Test Location	Origin Talinga	Cylinder No.	461 397
Calibration Date	03-May-14		310 459
Testo ID	ANE Testo 01		

APPENDIX B: PRE-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	0.00	0.00	-	0.0	0
	Actual	0.01	0.00	-	0.0	0
	Calibration	-	-	-	-	-
MID	Target	-	-	-	-	-
	Actual	-	-	-	-	-
	Calibration	-	-	-	-	-
HIGH	Target	15.20	21.30	-	23.6	511
	Actual	15.14	21.50	-	24.8	493
	Calibration	-	21.30	-	23.6	511





APPENDIX B: MULTI-POINT CALIBRATION 350			
Test Location	Origin Talinga	Cylinder No.	461 397
Calibration Date	03-May-14		310 459
Testo ID	ANE Testo 03		

APPENDIX B: PRE-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	-	0.00	0	0.0	0
	Actual	-	0.08	0	0.0	0
	Calibration	-	-	-	-	-
MID	Target	-	-	-	-	-
	Actual	-	-	-	-	-
	Calibration	-	-	-	-	-
HIGH	Target	-	21.30	995	23.6	511
	Actual	-	21.55	982	26.7	500
	Calibration	-	21.30	995	23.6	511





APPENDIX B: MULTI-POINT CALIBRATION 350			
Test Location	ANE Capalaba	Cylinder No.	461 397
Calibration Date	28-May-14		310 459
Testo ID	ANE Testo 01		

APPENDIX B: POST-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	0.00	0.00	-	0.0	0
	Actual	0.03	0.09	-	0.0	0
	Calibration	-	-	-	-	-
HIGH	Target	15.20	21.30	-	23.6	511
	Actual	15.21	21.46	-	23.6	524
	Calibration	-	-	-	-	-





APPENDIX B: MULTI-POINT CALIBRATION 350			
Test Location	ANE Capalaba	Cylinder No.	429 847
Calibration Date	19-May-14		310 459
Testo ID	ANE Testo 03		

APPENDIX B: POST-TEST CALIBRATION						
Range		CO <sub>2</sub>	O <sub>2</sub>	NO	NO <sub>2</sub>	CO
LOW	Target	-	0.00	0	0.0	0
	Actual	-	0.24	0	0.0	0
	Calibration	-	-	-	-	-
HIGH	Target	-	20.90	479	23.6	197
	Actual	-	20.90	479	23.9	199
	Calibration	-	-	-	-	-

