



Air Noise Environment
Environmental Monitoring and Assessment

Emissions Monitoring: Talinga GPF

Origin Energy

144 Montague Road
West End
QLD, 4101

November 2015

Issued: 9 November 2015

Prepared by:
Air Noise Environment

ABN: 13 081 834 513

This document is issued in accordance with NATA's accreditation requirements.



**WORLD RECOGNISED
ACCREDITATION**





This document is issued in accordance with NATA's accreditation requirements. The results of tests and/or measurements included in this document are traceable to international standards.

NATA Accreditation Number: 15841

Accredited for compliance with ISO/IEC 17025

Should you have any queries regarding the contents of this document, please contact Air Noise Environment.

Brisbane Office

A: Unit 3, 4 Tombo Street,

Capalaba, QLD 4157

T: +61 7 3245 7808

E: gld@ane.com.au






DOCUMENT CONTROL SHEET

Document Details

Project Reference: 4121
 Document Title: Emissions Monitoring: Talinga GPF
 Client: Origin Energy
 Document Reference: /Network/Projects/4121/Reporting/4121 Report02.odt

Revision History

Version:	Author:	Approved by:	Function:	Signature:
00	Samuel Putland	Claire Richardson	Technical Reviewer	
01	Samuel Putland	Claire Richardson	Technical Reviewer	
02	Samuel Putland	Gary Hall	Technical Reviewer	

Copyright:

Air Noise Environment retains ownership of the copyright to all reports, drawings, designs, plans, figures and other work produced by Air Noise Environment Pty Ltd during the course of fulfilling a commission. The client named on the cover of this document shall have a licence to use such documents and materials for the purpose of the subject commission provided they are reproduced in full or, alternatively, in part with due acknowledgement to Air Noise Environment. Third parties must not reproduce this document, in part or in full, without obtaining the prior permission of Air Noise Environment Pty Ltd.

Disclaimer:

This document has been prepared with all due care and attention by professional environmental practitioners according to accepted practices and techniques. This document is issued in confidence and is relevant only to the issues pertinent to the subject matter contained herein. Air Noise Environment Pty Ltd holds no responsibility for misapplication or misinterpretation by third parties of the contents of this document. If the revision history does not state that a Final version of the document has been issued, then it remains a draft. Draft versions of this document should not be relied upon for any purpose by the client, regulatory agencies or other interested parties.

Where site inspections, testing or fieldwork have taken place, the report is based on the information made available by the client or their nominees during the visit, visual observations and any subsequent discussions with regulatory authorities. It is further assumed that normal activities were being undertaken at the site on the day of the site visit(s).

The validity and comprehensiveness of supplied information has not been independently verified and, for the purposes of this report, it is assumed that the information provided to Air Noise Environment Pty Ltd for the purposes of this project is both complete and accurate.



Table of Contents

	Executive Summary	5
	Table 1: Summary of Results.	5
1	Introduction	6
2	Methodology	7
2.1	Emission Testing	7
2.2	Deviation from Methods	7
3	Results	8
3.1	Process Conditions	8
3.2	Monitoring Results	9
3.3	Accuracy of Monitoring Results	16
	Appendix A – Glossary of Terms	17
	Appendix B – Gas Calibration Records	20

Index of Tables

	Table 1: Summary of Results.	5
	Table 1.1: Monitoring Locations and Parameters	6
	Table 2.1: Summary Of Emission Monitoring Methods	7
	Table 3.1: Process Conditions During Emissions Monitoring for Compressors	8
	Table 3.2: Process Conditions During Emissions Monitoring for Power Generators	8
	Table 3.3: Flow and Sample Characteristics for Reciprocating Compressors	10
	Table 3.4: Emissions Results for Reciprocating Compressors	11
	Table 3.5: Flow and Sample Characteristics for Screw Compressors	12
	Table 3.6: Emissions Results for Screw Compressors	13
	Table 3.7: Flow and Sample Characteristics for Power Generators	14
	Table 3.8: Emissions Results for Power Generators	15
	Table 3.9: Estimated Method Uncertainties	16



Executive Summary

Table 1 Presents a summary of results from emissions monitoring completed at the Origin Talinga Gas Processing Facility during the period 13th - 19th August 2015. Results that do not comply with the release limits are highlighted in bold.

Table 1: Summary of Results.

Release Point		Velocity (m/s)	NO _x (expressed as NO ₂) (g/s)
Reciprocating Compressors	K4406-01.1	37.9	0.444
	K4406-01.2	20.9	0.489
	K4406-02.1	38.4	0.510
	K4406-02.2	21.6	0.356
	K4406-03.1	38.2	0.438
	K4406-03.2	24.2	0.247
Screw Compressors	K4404-01.1	32.9	6.630
	K4404-02.1	33.2	5.900
	K4404-03.1	33.1	0.770
	K4404-05.1	28.7	4.210
	K4404-06.1	31.6	1.010
	K4404-07.1	33.0	0.360
	K4404-08.1 ^a	31.7	3.840
	K4404-12.1	33.2	5.660
Power Generation	G4408-01.1	8.8	0.749
	G4408-02.1	12.1	1.260
	G4408-03.1	7.9	0.888

a. A minor exhaust leak on a sample line may underestimate emissions results from testing of K4404-08.1

Technician Comments

Origin personnel advised that tuning of gas compressor engines was not completed prior to annual emissions testing which is the preferred approach.



1 Introduction

Origin Energy commissioned Air Noise Environment Pty Ltd to conduct monitoring of air emissions from their Talinga Facility as part of their requirements under the Queensland Department of Environment and Resource Management Environmental Authority for the facility.

Table 1.1 details the monitoring locations and the monitoring performed at each location. The monitoring was completed during the period 13th - 19th August 2015.

Table 1.1: Monitoring Locations and Parameters

Parameter	NO _x	Velocity	Temperature & Moisture	O ₂ , CO ₂ & CO
Reciprocating Compressor K4404-01.1	x	x	x	x
Reciprocating Compressor K4404-01.2	x	x	x	x
Reciprocating Compressor K4404-02.1	x	x	x	x
Reciprocating Compressor K4404-02.2	x	x	x	x
Reciprocating Compressor K4404-03.1	x	x	x	x
Reciprocating Compressor K4404-03.2	x	x	x	x
Screw Compressor K4404-01.1	x	x	x	x
Screw Compressor K4404-02.1	x	x	x	x
Screw Compressor K4404-03.1	x	x	x	x
Screw Compressor K4404-05.1	x	x	x	x
Screw Compressor K4404-06.1	x	x	x	x
Screw Compressor K4404-07.1	x	x	x	x
Screw Compressor K4404-08.1	x	x	x	x
Screw Compressor K4404-12.1	x	x	x	x
Power Generator G4408-01.1	x	x	x	x
Power Generator G4408-02.1	x	x	x	x
Power Generator G4408-03.1	x	x	x	x

The monitoring of air emissions at the Talinga Facility was completed during normal operating conditions. Any factors that may have affected the monitoring results were not observed by, or brought to the notice of Air Noise Environment (ANE) staff except where noted in this report.



2 Methodology

2.1 Emission Testing

Table 2.1 below lists the Methods used when undertaking emission monitoring at Talinga Facility.

All air quality monitoring undertaken by the Company has been undertaken in accordance with the methods identified in Table 2.1 below unless as specified in Section 2.3.

Table 2.1: Summary Of Emission Monitoring Methods

Measurement Parameter	Method Equivalency
Sampling Positions	AS 4323.1-1995 Method 1: selection of sampling positions
Velocity, Flowrate and Temperature	AS 4323.2-1995 Stationary Source Emissions - Method 2: Determination of Total Particulate Matter - Isokinetic Manual Sampling - Gravimetric Method
Oxygen and Carbon Dioxide	USEPA Method 3A Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources
Moisture Content	USEPA Method 4 Determination of Moisture Content in Stack Gases
Oxides of Nitrogen (NO, NO ₂ , NO _x)	USEPA Method 7E Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental Analyzer Procedure)
Carbon Monoxide	USEPA Method 10B Determination of Carbon Monoxide Emissions from Stationary Source

2.2 Deviation from Methods

None.



3 Results

3.1 Process Conditions

Table 3.1 provides a summary of process conditions during the air emissions monitoring at Talinga Facility.

Table 3.1: Process Conditions During Emissions Monitoring for Compressors

Parameter	Average Engine Load (%)	Average Engine RPM
Reciprocating Compressor K4406-01.1	101	999
Reciprocating Compressor K4406-01.2		
Reciprocating Compressor K4406-02.1	100	1000
Reciprocating Compressor K4406-02.2	101	1000
Reciprocating Compressor K4406-03.1	104	1000
Reciprocating Compressor K4406-03.2		
Screw Compressor K4404-01.1	103	1203
Screw Compressor K4404-02.1	102	1201
Screw Compressor K4404-03.1	91	1165
Screw Compressor K4404-05.1	86	1202
Screw Compressor K4404-06.1	94	1203
Screw Compressor K4404-07.1	101	1205
Screw Compressor K4404-08.1 ^a	102	1200
Screw Compressor K4404-12.1	100	1205

a. A minor exhaust leak on a sample line may underestimate emissions results from testing completed

Table 3.2: Process Conditions During Emissions Monitoring for Power Generators

Parameter	Generator Load (kW)	Average Engine RPM	Combustion Temperature (°C)
Power Generation G4408-01.1	110	1500	43.1
Power Generation G4408-02.1	109	1501	49.2
Power Generation G4408-03.1	102	1500	46.8



3.2 Monitoring Results

The results of the emissions monitoring for the Talinga Facility completed during the period of 13th - 19th August 2015 are provided in Table 3.3 to Table 3.5.

Table 3.3: Flow and Sample Characteristics for Reciprocating Compressors

Parameter	K4406-01.1	K4406-01.2	K4406/02.1	K4406-02.2	K4406-03.1	K4406-03.2
Date (dd/mm/yy)	17/08/15		15/08/15	17/08/15	14/08/15	
Run Times:						
Moisture	14:03 – 14:43	15:08 – 15:48	08:37 – 09:17	12:29 – 13:09	12:04 – 12:44	14:18 – 14:58
CO ₂ , O ₂ , CO, NO _x	14:05 – 14:43	15:11 – 16:10	08:44 – 09:42	12:23 – 13:38	12:32 – 13:28	14:21 – 15:47
Moisture Sample Volume (m ³)	0.417	0.423	0.404	0.412	0.403	0.415
Average Stack Temperature (°C)	396	328	416	344	396	335
Stack Diameter (m)	0.50					
Barometric Pressure (kPa)	102.12	102.12	102.17	102.12	102.17	102.17
Calculated Stack Moisture (%)	10.3	7.7	10.7	9.2	8.1	10.3
Carbon Dioxide Percentage (%)	5.30	5.49	4.53	5.69	4.45	4.79
Oxygen Percentage (%)	12.02	11.74	11.59	11.28	12.64	12.45
Dry Gas Molecular Weight (g/gmole)	29.33	29.35	29.19	29.36	29.22	29.26
Average Stack Gas Velocity (m/s)	37.9	20.9	38.4	21.6	38.2	24.2
Actual Stack Flow Rate (m ³ /s)	7.5	4.1	7.6	4.3	7.5	4.8
Dry Standard Stack Flow Rate (Nm ³ /s)	2.7	1.7	2.7	1.7	2.8	1.9

Table 3.4: Emissions Results for Reciprocating Compressors

Parameter		K4406-01.1	K4406-01.2	K4406-02.1	K4406-02.2	K4406-03.1	K4406-03.2
NO _x (expressed as NO ₂)	(mg/Nm ³)	162	283	190	207	154	128
	(g/s)	0.44	0.489	0.510	0.356	0.438	0.247
CO	(mg/Nm ³)	451	511	492	523	461	496
	(g/s)	1.24	0.89	1.33	0.901	1.31	0.96

Table 3.5: Flow and Sample Characteristics for Screw Compressors

Parameter	K4404-01	K4404-02	K4404-03	K4404-05	K4404-06	K4404-07	K4404-08	K4404-12
Date (dd/mm/yyyy)	18/08/15					19/08/15		
Run Times:								
Moisture	08:38 – 09:18	10:11 – 10:51	11:45 – 12:25	13:31 – 14:11	15:06 – 15:46	11:38 – 12:18	10:28 – 11:15	08:48 – 09:28
CO ₂ , O ₂ , CO, NO _x	08:41 – 09:48	10:12 – 11:17	11:48 – 12:55	13:33 – 14:33	15:07 – 15:58	11:40 – 12:24	10:29 – 11:15	08:52 – 09:59
Moisture Sample Volume (m ³)	0.416	0.394	0.401	0.404	0.415	0.400	0.401	0.385
Average Stack Temperature (°C)	483	475	468	448	455	471	464	467
Stack Diameter (m)	0.35							
Barometric Pressure (kPa)	102.16					102.47		
Calculated Stack Moisture (%)	15.1	19.1	17.3	16.5	16.3	18.6	17.4	16.5
Carbon Dioxide Percentage (%)	11.36	10.82	11.58	11.48	11.18	11.73	11.18	9.46
Oxygen Percentage (%)	0.94	2.18	1.07	1.52	2.16	1.20	1.96	4.50
Dry Gas Molecular Weight (g/g-mole)	29.86	29.82	29.90	29.90	29.87	29.92	29.87	29.69
Average Stack Gas Velocity (m/s)	32.9	33.2	33.1	28.7	31.6	33.0	31.7	33.2
Actual Stack Flow Rate (m ³ /s)	3.2	3.2	3.2	2.8	3.0	3.2	3.1	3.2
Dry Standard Stack Flow Rate (Nm ³ /s)	1.0	1.0	1.0	0.9	1.0	1.0	1.0	1.0

Table 3.6: Emissions Results for Screw Compressors

Parameter		K4404-01	K4404-02	K4404-03	K4404-05	K4404-06	K4404-07	K4404-08	K4404-12
NO _x (expressed as NO ₂)	(mg/Nm ³)	6750	6190	778	4769	1040	371	4059	5683
	(g/s)	6.63	5.90	0.77	4.21	1.01	0.36	3.84	5.66
CO	(mg/Nm ³)	3250	3155	503	163	149	678	330	1460
	(g/s)	3.19	3.01	0.50	0.144	0.144	0.653	0.312	1.45

Table 3.7: Flow and Sample Characteristics for Power Generators

Parameter	G4408-01.1	G4408-02.1	G4408-03.1
Date (dd/mm/yyyy)	13/08/15		
Run Times:			
Moisture	12:23 – 13:03	13:48 – 14:28	15:19 – 15:59
CO ₂ , O ₂ , CO, NO _x	12:31 – 13:25	13:50 – 14:46	15:21 – 16:13
Moisture Sample Volume (m ³)	0.406	0.402	0.402
Average Stack Temperature (°C)	406	393	421
Stack Diameter (m)	0.20		
Barometric Pressure (kPa)	102.17		
Calculated Stack Moisture (%)	16.5	15.8	16.6
Carbon Dioxide Percentage (%)	9.31	9.28	10.51
Oxygen Percentage (%)	3.84	4.82	3.01
Dry Gas Molecular Weight (g/g-mole)	29.64	29.68	29.80
Average Stack Gas Velocity (m/s)	8.8	12.1	7.9
Actual Stack Flow Rate (m ³ /s)	0.28	0.38	0.25
Dry Standard Stack Flow Rate (Nm ³ /s)	0.09	0.13	0.08

Table 3.8: Emissions Results for Power Generators

Parameter		G4408-01.1	G4408-02.1	G4408-03.1
NO _x (expressed as NO ₂)	(mg/Nm ³)	7967	9578	10805
	(g/s)	0.749	1.26	0.888
CO	(mg/Nm ³)	491	484	521
	(g/s)	0.046	0.064	0.043



3.3 Accuracy of Monitoring Results

Table 3.9 presents a summary of the estimated method uncertainties for each of the monitoring parameters.

Table 3.9: Estimated Method Uncertainties

Measurement Parameter	Method	% Uncertainty
Oxygen	USEPA Method 3A	12
Carbon Dioxide		10
Oxides of Nitrogen (NO, NO ₂ , NO _x)	USEPA Method 7E	10
Carbon Monoxide	USEPA Method 10B	

Uncertainty values cited are calculated at a 95% confidence level, with a coverage factor of 2.




Appendix A – Glossary of Terms



APPENDIX A: GLOSSARY OF TERMS

<	The analytes tested for was not detected, the value stated is the reportable limit of detection
µg	Micrograms (10 ⁻⁶ grams)
AS	Australian Standard
dscm	dry standard cubic meters (at 0°C and 1 atmosphere)
g	grams
kg	kilograms
m	metres
m ³	Cubic Metres, actual gas volume in cubic metres as measured.
mg	Milligrams
min	Minute
mg/m ³	Milligrams (10 ⁻³) per cubic metre.
mmH ₂ O	Millimetres of water
Mole	SI Unit defined as an amount of a substance that contains as many elementary entities (e.g. atoms, molecules, ions, electrons) as there are atoms in 12 grams of pure Carbon-12 (¹² C)
N/A	Not Applicable
ng	Nanograms (10 ⁻⁹ grams)
Nm ³	Normalised Cubic Metres - Gas volume in dry cubic metres at standard temperature and pressure (0°C and 101.3 kPa).
ou	Odour Units
°C	Degrees Celsius
µg/m ³	Micrograms (10 ⁻⁶) per cubic metre.
ppb / ppm	Parts per billion / million.
PM	Particulate Matter.




APPENDIX A: GLOSSARY OF TERMS

PM ₁₀ , PM _{2.5} , PM ₁	Fine particulate matter with an equivalent aerodynamic diameter of less than 10, 2.5 or 1 micrometres respectively. Fine particulates are predominantly sourced from combustion processes. Vehicle emissions are a key source in urban environments.
sec	Second
Sm ³	Standardised Cubic Metres - Gas volume in dry cubic metres at standard temperature and pressure (0°C and 101.3 kPa) and corrected to a standardised value (e.g. 7% O ₂).
STP	Standard Temperature and Pressure (0°C and 101.3 kPa).
TVOC	Total Volatile Organic Compounds. These compounds can be both toxic and odorous.
USEPA	United States Environmental Protection Agency



Appendix B – Gas Calibration Records



APPENDIX C: GAS CALIBRATION RECORDS


Test Location:	ANE Office	Cylinder No.	356 615
Calibration Date:	11-Aug-15 21-Aug-15		461 397
Testo ID:	ANE 01		429 829

Pre Test Calibration

Range		CO ₂ %	O ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO ₂ ppm
LOW	Target	-	-	0	0	0	0.0
	Actual	-	-	0	0	0	0.0
	Calibration	-	-	-	-	-	-
HIGH	Target	-	-	511	437	1010	22.5
	Actual	-	-	513	450	990	20.3
	Calibration	-	-	-	437	1010	22.6

Post Test Calibration

Range		CO ₂ %	O ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO ₂ ppm
LOW	Target	-	-	0	0	0	0.0
	Actual	-	-	0	13	1	0.0
MID	Target	-	-	511	437	1010	22.5
	Actual	-	-	494	396	1020	24.5



APPENDIX C: GAS CALIBRATION RECORDS			
Test Location:	SIMTARS Redbank# ANE Office	Cylinder No.	356 615 461 397 429 829
Calibration Date:	19-Feb-15 27-Aug-15		
Testo ID:	SIMTARS 04741		

#SIMTARS Calibration Report OG490988N2

Pre Test Calibration							
Range		CO ₂ %	O ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO ₂ ppm
LOW	Target	0.00	0.00	-	-	-	-
	Actual	0.00	0.00	-	-	-	-
	Calibration	-	-	-	-	-	-
HIGH	Target	25.00	20.95	-	-	-	-
	Actual	24.79	20.92	-	-	-	-
	Calibration	-	-	-	-	-	-

Post Test Calibration							
Range		CO ₂ %	O ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO ₂ ppm
LOW	Target	0.00	0.0	-	-	-	-
	Actual	0.04	0.0	-	-	-	-
MID	Target	13.80	6.00	-	-	-	-
	Actual	14.30	6.05	-	-	-	-